



NOTES

1. ALL METAL SURFACES ABOVE GROUND SHALL BE DEGREASED AND PAINTED WITH ONE COAT OF RED PRIMER AND TWO COATS OF DEEP BLUE FINISH. (RUSTOLEUM OR APPROVED EQUAL)
2. CONCRETE SHALL BE COMMERCIAL GRADE, CLASS 3300 P.S.I. 1½" MAX. AGGREGATE SIZE, PER 2002 ODOT/APWA SPECS.
3. THRUST RODS AND/OR REBAR EXPOSED TO SOIL SHALL BE ZINC COATED
4. PROVIDE AN APPROVED EXTENSION STEM WHEN OPERATING NUT IS IN EXCESS OF 24" BELOW FINISHED GRADE

NO. DATE INITIAL REVISIONS				CITY OF GRANTS PASS ENGINEERING DIVISION	
1	5/02	FMS		4" BLOW-OFF ASS'Y (LOW POINT)	
2	2/05	FMS	STD DWG UPDATE		
DESIGN: STAFF				DRAWN: FMS	
				APPROVED: DAP	
				SCALE: NONE	DWG. NO. 205-B