



NOTES

1. ALL METAL SURFACES ABOVE GROUND SHALL BE DEGREASED AND PAINTED WITH ONE COAT OF RED PRIMER AND TWO COATS OF DEEP BLUE FINISH. (RUSTOLEUM OR APPROVED EQUAL)
2. CONCRETE SHALL BE A MIN OF 6 SACKS (570#) OF CEMENT PER CUBIC YARD AND SHALL REACH 3300 P.S.I. IN 28 DAYS
3. THRUST RODS AND/OR REBAR EXPOSED TO SOIL SHALL BE ZINC COATED
4. ALL VALVES WITH OPERATING NUTS MORE THAN 24" DEEP SHALL BE PROVIDED WITH OPERATOR EXTENSIONS PER GPSD NO. 217

NO.	DATE	INITIAL	REVISIONS	CITY OF GRANTS PASS ENGINEERING DIVISION
2	2/05	FMS	WATER STD DWG UPDATE	
				4" BLOW-OFF ASS'Y (END OF LINE)
DESIGN: STAFF		DRAWN: FMS	APPROVED: DAP	SCALE: NONE
				DWG. NO. 205-A