



NOTES:

AN ENCROACHMENT PERMIT IS REQUIRED FOR ALL WORK WITHIN THE RIGH-OF-WAY & SHALL BE PERFORMED BY A LICENSED PLUMBER OR CONTRACTOR, CURRENTLY PRE-QUALIFIED WITH THE CITY OF GRANTS PASS.

A WHITE TOP METAL FENCE POST SHALL BE PLACED AT THE LATERAL END, WITH 12" MIN. PROJECTING ABOVE THE GROUND LINE. TWO OR MORE METAL FENCE POSTS WIRED TOGETHER MAY BE REQUIRED FOR DEEP LATERALS.

ON NEW CONSTRUCTION, ONLY MANUFACTURED TEES OF THE SAME MATERIAL AS THE MAIN SHALL BE USED.

NON-METALLIC SERVICES SHALL BE ENTWINED (MIN. THREE TURNS) WITH 18 GAUGE INSULATED COPPER WIRE, GREEN IN COLOR, FOR THE FULL LENGTH, WITH THE END LEFT ABOVE FINISHED GRADE.

IF THE BACKFILL HEIGHT ABOVE THE TOP OF THE MAIN IS EQUAL TO OR GREATER THAN 12', THE FIRST SECTION OF SERVICE CONNECTION PIPE SHALL BE A STANDARD LENGTH OF APPROVED CAST IRON OR DUCTILE IRON PIPE.

LATERALS THAT ARE TUNNELED OR TRENCHED UNDER EXISTING CURB AND GUTTER OR OTHER UTILITIES SHALL BE BACKFILLED WITHIN 2' OF THE CROSSING WITH A ONE (1) SACK CEMENT SAND SLURRY MIX. (SEE GPSD #107.)

AN "S" SHALL BE STAMPED ON TOP OF NEW CURB, WHERE LATERAL CROSSES UNDER CURB.

THE UPPER END OF THE SERVICE CONNECTION PIPE SHALL BE 6' DEEP, FROM THE FLOW LINE TO TOP OF CURB OR FINISHED GROUND SERVICE, UNLESS OTHERWISE APPROVED BY ENGINEER.

TRENCHES SHALL NOT BE BACKFILLED UNTIL APPROVED BY ENGINEER. SEE GPSD #107.

ALL SANITARY SEWER SERVICES SHALL EXTEND THREE (3) FT. BEYOND R/W LINE. IF PUE EXISTS, EXTEND THREE (3) FT. BEYOND INTERIOR EASEMENT LINE.

NO.	DATE	INITIAL	REVISIONS
1	2/95	SLN	XFER TO AUTOCAD
2	6/95	SLN	ADOPTED BY CITY COUNCIL
3	6/04	FMS	SEWER STD DWG UPDATE
DESIGN: STAFF		DRAWN: SLN	APPROVED: DAP

CITY OF GRANTS PASS ENGINEERING DIVISION	
NEW SEWER SERVICE CONNECTION	
SCALE: NONE	DWG. NO. 304