



**NOTES**

1. WATER METER SHALL BE PROVIDED & INSTALLED BY THE CITY AFTER PAYMENT OF ALL CONNECTION FEES BY OWNER OR CONTRACTOR.
2. PLACE 3" PVC SLEEVE FROM METER SETTER OUTLET TO OUTSIDE OF SIDEWALK FOR CUSTOMER SERVICE LINE.
3. METER BOX TO BE FLUSH WITH FINISHED GRADE.
4. METAL LID REQUIRED FOR ALL INSTALLATIONS PER GPSD NO. 219.
5. CITY TO TAP LIVE WATER MAINS.
6. METERS-SETTERS - FORD ALL BRASS AND COPPER FOR FLANGE METERS EQUIPPED WITH CHECK VALVE ON OUTLET AND ANGLD BALL VALVE ON INLET SIDE WITH BYPASS. BYPASS SHALL REMAIN EXPOSED. MINIMUM 3" CLEARANCE UNDER BYPASS. SETTER TO BE CENTERED IN BOX.
7. NO SERVICE SHALL BE INSTALLED CLOSER THAN 5 FEET TO A PROPERTY CORNER. (SEE INSET, GPSD NO. 203)
8. ALL VALVES WITH OPERATING NUTS MORE THAN 24" DEEP SHALL BE SUPPLIED WITH OPERATOR EXTENSIONS PER GPSD NO. 217.
9. NO PRIVATE VALVES OR APPURTENANCES ALLOWED IN SIDEWALK OR RIGHT-OF-WAY.

FORD  
 VBH76 - 18Bx11x66 1 1/2" (13" LAY LENGTH)  
 VBH77 - 18Bx11x77 2" (17" LAY LENGTH)  
 OR APPROVED EQUAL

NO.	DATE	INITIAL	REVISIONS	CITY OF GRANTS PASS ENGINEERING DIVISION		
3	1/04	FMS	UPDATE	1 1/2" & 2" WATER SERVICE SCALE: NONE DWG. NO. 204		
4	2/05	FMS	WATER STD DWG UPDATES			
5	11/10	GLV	FLIP METER ASSEMBLY			
DESIGN: STAFF			DRAWN: SLN			APPROVED: DAP
			SCALE: NONE			DWG. NO. 204