



General Notes:

1. Install a 3' x 3' x 4" concrete pad flush to existing grade when in unimproved areas.
2. See concrete standards page for additional requirements.
3. Cleanout pipe shall be same material and size as sewer main.
4. Fill material in excavated area shall be as approved by City Engineer.
5. Min. 3" asphaltic concrete if cleanout is in paved roadway. Outside roadway, concrete pad to be flush with ring.
6. Joint at ring and cover shall not exceed 2', max.
7. 3" min. clearance between bottom of cover and top of plug.

The selection and use of this standard drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.

Designed By:	STAFF
Drawn By:	KJD
Checked By:	MPT
Approved:	JMC

No.	Date	Revisions	App. By



CITY OF GRANTS PASS
 101 Northwest 'A' Street
 Grants Pass, OR 97526
 (541) 450-6060 ph (541) 476-9218 fax

SANITARY SEWER CLEANOUT

2018

DWG. NO. GP362