



General Notes

1. All metal surfaces above ground shall be degreased and painted with one coat of red primer and two coats of deep blue finish (rustoleum or approved equal).
2. See concrete standards for pads.
3. Thrust rods and/or rebar exposed to soil shall be zinc coated.
4. All valves with operating nuts more than 24" deep shall be provided with operator extensions per Std. Dwg. GP258.

The selection and use of this standard drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.		Designed By: STAFF	
		Drawn By: KJD	
		Checked By: MPT	
		Approved: JMC	
No.	Date	Revisions	App. By



CITY OF GRANTS PASS
 101 Northwest 'A' Street
 Grants Pass, OR 97526
 (541) 450-6060 ph (541) 476-9218 fax

**4" BLOW-OFF ASSEMBLY
 (END OF LINE)**

2018

DWG. NO. GP263