



General Notes

1. All metal surfaces above ground shall be degreased and painted with one coat of red primer and two coats of deep blue finish (rustoleum or approved equal).
2. See concrete standards for pads.
3. Thrust rods and/or rebar exposed to soil shall be zinc coated.
4. Provide an approved extension stem when operating nut is in excess of 24" below finished grade.

The selection and use of this standard drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.			
Designed By:	STAFF		
Drawn By:	KJD		
Checked By:	MPT		
Approved:	JMC		
No.	Date	Revisions	App. By



CITY OF GRANTS PASS
 101 Northwest 'A' Street
 Grants Pass, OR 97526
 (541) 450-6060 ph (541) 476-9218 fax

4" BLOW-OFF ASSEMBLY (LOW POINT)

2018

DWG. NO. GP264