



General Notes

1. Water meter shall be provided & installed by the City after payment of all connection fees by owner or contractor.
2. Place 3" pvc sleeve from meter setter outlet to outside of sidewalk for customer service line.
3. Meter box to be flush with finished grade.
4. Metal lid required for all installations per Std. Dwg. GP219.
5. City to tap live water mains.
6. Meter-setters - Ford all brass and copper for flange meters equipped with check valve on outlet and angled ball valve on inlet side with bypass. Bypass shall remain exposed. Minimum 3" clearance under bypass. Setter to be centered in box.
7. No service shall be installed closer than 5 feet to a property corner. (see inset, Std. Dwg. GP274)
8. All valves with operating nuts more than 24" deep shall be supplied with operator extensions per Std. Dwg. GP258.
9. No private valves or appurtenances allowed in sidewalk or right-of-way.

Ford

VBH76 - 18B - 11 - 66 1 1/2" (13" lay length)
 VBH77 - 18B - 11 - 77 2" (17" lay length)
 or approved equal

The selection and use of this standard drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.		Designed By: STAFF
		Drawn By: KJD
		Checked By: MPT
		Approved: JMC



CITY OF GRANTS PASS
 101 Northwest 'A' Street
 Grants Pass, OR 97526
 (541) 450-6060 ph (541) 476-9218 fax

1 1/2" & 2" WATER SERVICE

2018

DWG. NO. GP275

No.	Date	Revisions	App. By